

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243522
Address: 2809 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Drew Fischer	Partial	Friday, March 13, 2026

Corrective Action Required:

1	Misc	Erosion control in place at time of inspection 3/4/26 Tyler S. Mud has been tracked out from driveway and from each side of the driveway into the road. Looks like yard is graded for sod, however we cannot track mud into the road and all over driveway and sidewalks. need to clean up asap. Fail.
---	------	---

Comments: