

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20253879
Address: 2229 SW HEARTLAND CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Failed	Friday, March 13, 2026

Corrective Action Required:

1	Misc	229 SW Heartland Ct
		- complete final grade , install sod and splash blocks
		- Seal all exterior penetrations
		- Label sump and irrigation outlets as non gfci
		-

Comments: