

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235208
Address: 2911 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Friday, March 13, 2026

Corrective Action Required:

1 CORRIDORS

OK:
-2nd to 4th fl above-ceiling

****Correcrtions:**

-1st fl corridor-Support low voltage cables; fc all membrane penetrations, not with mud
-lower level corridor-fc all membrane penetrations

Comments: