

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20243522  
Address: 2809 SW HEARTLAND RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Drew Fischer	Failed	Friday, March 13, 2026

Corrective Action Required:

1	Misc	2809 SW Heartland Rd - as graded plot plan needed - Final driveway and sidewalk inspections needed - Final grade , sod and splash blocks needed - Install missing light fixture in laundry room - Install missing floodlight on rear of house - Label sump outlet as non gfci -
---	------	--

Comments: