

March 13, 2026



Joe Frogge  
City of Lee's Summit Plans Examiner  
220 SE Green Street  
Lee's Summit, MO 64063

ARCHITECTURE  
INTERIOR DESIGN  
ENGINEERING  
PLANNING

Project Name: Village of Discovery Park – Home2 Suites – Lot 2  
Project Address: 251 NE Alura Way, Lee's Summit, MO 64064  
Permit Number: PRCOM20241886

Dear Joe,

We are submitting "Changes to the Approved Plans" for the above referenced project and wanted to give you a brief description of those changes. These changes are related to the various shafts throughout the building. The changes are as follows:

1. G-100 – Updated Code Plan by changing fire rating of shafts 2, 3, 4, and 5 from 2 hour to 1 hour since shafts only connect the top three floors.
2. G-101 – Updated Code Plan by changing fire rating of shafts 2, 3, 4, and 5 from 2 hour to 1 hour since shafts only connect the top three floors
3. G-102 – Updated Code Plan by changing fire rating of shafts 2, 3, 4, and 5 from 2 hour to 1 hour since shafts only connect the top three floors
4. A-102 – Updated building second floor plan by labeling the shafts 1, 2, 3, 4, and 5.
5. A-103 – Updated building third floor plan by labeling the shafts 1, 2, 3, 4, and 5.
6. A-104 – Updated building fourth floor plan by labeling the shafts 1, 2, 3, 4, and 5.
7. A-308 – Added new sheet to help clarify each of the shafts within the building. In addition, provided details, including UL Design information, for enclosing bottom of shafts 4 and 5 with a 1 hour rated horizontal barrier at the floor/ceiling to limit shaft height to three stories.

If you have any questions, please contact us.

Should you have any questions, please do not hesitate to call.

Sincerely yours,

**ROSEMANN & ASSOCIATES, P.C.**

A handwritten signature in blue ink, appearing to read "David E. Hendrikse".

David E. Hendrikse, AIA  
Vice President