



**BOB D. CAMPBELL & CO.**

Structural Engineers Since 1957  
4338 Belleview Ave. 816.531.4144  
Kansas City, MO 64111 www.bdc-engrs.com

PRINCIPALS

*President*

Christopher A. Beverlin, P.E.

Clark A. Basinger, P.E.

Wayne E. Davis, P.E.

Jeffrey L. Wright, P.E.

Christopher W. Boos, P.E.

Brandon M. Ford, P.E.

Steven J. Brooks, P.E.

Ryan M. Hagedorn, P.E.

Michael L. Falk, P.E.

*Administrative Manager*

James M. Spena

March 10, 2026

Mark Murdick  
Sullivan Palmer Architects  
8621 Johnson Drive  
Merriam, KS 66202

Re: Review of Kitchen Hood Addition  
Martin City Pizza & Taproom  
354 SW Blue Parkway  
Lee's Summit, Missouri

Dear Mark:

Per your request, we have reviewed the proposed suspended and rooftop additions to the above referenced existing building. The proposed building additions are as follows:

- 1) Kitchen Hood (suspended from roof bar joists)  
Footprint = 10'-6" x 6'-8"  
Weight = 644 lbs
- 2) Roof Top Make Up Air Addition (set atop roof joists)  
Footprint = 1'-9" x 5'-11"  
Weight = 600 lbs
- 3) Exhaust Fan (set atop roof joists)  
Footprint = 2'-2" x 2'-2"  
Weight = 250 lbs

The bar joists are supported by 24" deep bar joists at 5'-0" centers spanning 31'-8". Evaluation of existing bar joists indicated adequate structural capacity to safely support the proposed suspended and roof top addition loadings.

Sincerely,

**BOB D. CAMPBELL & CO.**  
Structural Engineers

Michael J. Falbe, P.E., Principal

MJF / js

cc: File / PR2603

