

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20235208  
Address: 2911 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Khanh Nguyen	Failed	Tuesday, March 17, 2026

Corrective Action Required:

1 LOWER LEVEL Units, corridor, and balconies-OK

Corrective Action Required:

2 FIRST FLOOR  
-Pre-rock for corridor ceiling-OK  
-Dwelling units OK  
-Balconies OK

Garages and storage:

-Provide full fire-stop collar for 6" roof drain in G9 storage

Corrective Action Required:

3 SECOND FLOOR Units, corridor, and balconies-OK

Corrective Action Required:

4 THIRD FLOOR Units, corridor, and balconies-OK

Corrective Action Required:

5 FOURTH FLOOR Units, corridor, and balconies-OK

Corrective Action Required:

6 STAIR TOWER 1 \*\*THIS IS NORTH STAIR

All rough OK

Informational:

7 STAIR TOWER 2 \*\*THIS IS SOUTH STAIR

Corrective Action Required:  
8 STAIR TOWER 3 All rough OK  
\*\*THIS IS REAR STAIR

Informational:  
9 ELEVATOR 1 All rough OK  
Complete

Corrective Action Required:  
10 Misc Interior and exterior sheathed shear walls:  
-Lower floor, 1st, 2nd fl  
-All outlet boxes for box extensions where required on 2nd to 4th floor

**Comments:**