

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251178
Address: 11 NE SYCAMORE ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Tuesday, March 17, 2026

Corrective Action Required:

1 THIRD FLOOR Approved

Corrective Action Required:

2 SECOND FLOOR Pre rock behind tubs ok to cover
208, 202, 206, 204- Nail T stud at overbored stud 12" oc min
203-Add stud 16" oc max at exterior wall/party wall

Corrective Action Required:

3 FIRST FLOOR Pre rock behind tubs ok to cover

Comments: