

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

Inspection Summary

Permit #: PRCOM20120415, Building Permit - Commercial Address: 2401 NE DOUGLAS ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Mike Copeland Failed Tuesday, May 22, 2012

Inspection - Codes Commercial

Corrective Action Required

1 MISC *THIS INSPECTION ONLY COVERS THE 1ST SPRAY BOOTH. THE

2ND SPRAY BOOTH IS NOT INSTALLED YET.

CORRECT THE FOLLOWING FOR THE 1ST SPRAY BOOTH:

-OUTSIDE DIFFUSERS

-SECURE ALL THE MC CABLES ABOVE THE BOOTH

-CONDUIT TO MIXING RM SEALED BOTH SIDE?

*OK TO USE THE BOOTH

Corrective Action Required

2 MUST RECIEVE PLANNING APPROVAL FOR THIS PROJECT

BEFORE CLOSING THIS PERMIT.

CONCERNS AS TO THE ACCESSABLE PARKINIG.

Comments: