

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20253864
Address: 3801 SW LONGVIEW RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Shawn Hoffman	Failed	Wednesday, March 18, 2026

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | - NO FINAL INSPECTION CALLED IN. |
| | | - COMPLETE ALL ENGINEERING INSPECTIONS |
| | | - NO INSPECTION OF ELECTRICAL OF BASES OF 3 LIGHT POLE AT SIDEWALK NEAR PARKING LOT. |
| | | - upload third party inspection on torq specs of shade structure. |
| | | - 3 Light pole bases North on sidewalk near parking lot. Not inspected and not on plans. |

Comments: