

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251416

Address: 623 SE LINDBERG LN, LEES SUMMIT, MO 64063625 SE LINDBERG LN, LEES SUMMIT, MO 64063627
SE LINDBERG LN, LEES SUMMIT, MO 64063621 SE LINDBERG LN, LEES SUMMIT, MO
64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Drew Fischer	Failed	Wednesday, March 18, 2026

Corrective Action Required:

1 Misc

623 - fireproof roof sheathing must extend 4' at all separation walls
- 623/625, F3 truss calls for lateral bracing , address with engineer , need letter uploaded to permit

Comments: