

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250017
Address: 620 SE HIGHLAND PARK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, March 19, 2026

Corrective Action Required:

1 Misc Address cut hold downs at PFH at front door

Informational:

2 Misc Following areas inspected
-garage pfh nailing
-front porch trusses
-front porch pfh nailing
-front of home osb nailing

Comments: