

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20255261
Address: 1001 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Robb Popp	Failed	Thursday, March 19, 2026

Corrective Action Required:

1	Misc	-Correct bar cut for plumbing sleeve -Provide min 3" clearance to earth at all bar -Remove loose soil and mud from footing -Provide proper bearing at bottom of footing
---	------	--

Comments: