

March 19, 2026



Joe Frogge  
City of Lee's Summit Plans Examiner  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)-696-1241  
Joe.Frogge@cityofls.net

ARCHITECTURE  
INTERIOR DESIGN  
ENGINEERING  
PLANNING

Project Name: Village of Discovery Park – Mixed Use Building – Lot 4  
Project Address: 1900 NE Discovery Ave, Lee's Summit, MO 64086  
Permit Number: PRCOM20230340

Dear Joe,

We are submitting "Changes to the Approved Plans" for the above referenced project and wanted to give you a brief description of those changes. These changes relate to revising elevator shaft and building fire separation wall construction from masonry construction to wood framed construction above the second floor. The changes are as follows:

1. G-001 – Updated Sheet Index.
2. G-101 – Added 2-hour rated wood framed wall assembly P18.
3. G-214 – Added UL Design U301 for 2-hour wood framed wall assembly.
4. G-215 – Added UL Design U301 for 2-hour wood framed wall assembly.
5. A-102 – Updated wall graphics and wall type call outs to wood framed on second floor plan.
6. A-103 – Updated wall graphics and wall type call outs to wood framed on third floor plan.
7. A-112 – Updated wall graphics and wall type call outs to wood framed on enlarged second floor plan – zone A.
8. A-113 – Updated wall graphics and wall type call outs to wood framed on enlarged second floor plan – zone B.
9. A-114 – Updated wall graphics and wall type call outs to wood framed on enlarged third floor plan – zone A.
10. A-115 – Updated wall graphics and wall type call outs to wood framed on enlarged third floor plan – zone B.
11. A-301 – Change wall section detail 1 to show wood framed wall above second floor level.
12. A-302 – Updated elevator shaft plans and sections to show wood framed wall above second floor level.



If you have any questions, please contact us.

Should you have any questions, please do not hesitate to call.

Sincerely yours,

**ROSEMANN & ASSOCIATES, P.C.**

David E. Hendrikse, AIA  
Vice President

Enclosure