

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20251178  
Address: 11 NE SYCAMORE ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Robb Popp	Partial	Friday, March 20, 2026

Corrective Action Required:		
1	THIRD FLOOR	Approved
Corrective Action Required:		
2	SECOND FLOOR	Approved
Corrective Action Required:		
3	FIRST FLOOR	Pre rock behind tubs ok to cover

**Comments:**