

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251178
Address: 11 NE SYCAMORE ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Partial	Friday, March 20, 2026

Corrective Action Required:

1	THIRD FLOOR	-Screw pattern and tape at pre rock ok -RC at units approved
---	-------------	---

Corrective Action Required:

2	SECOND FLOOR	-Screw pattern and tape at pre rock ok -RC at units approved
---	--------------	---

Corrective Action Required:

3	FIRST FLOOR	-Screw pattern and tape at pre rock ok
---	-------------	--

Comments: