

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251410

Address: 618 SE BRADFREE ST, LEES SUMMIT, MO 64063620 SE BRADFREE ST, LEES SUMMIT, MO 64063622
SE BRADFREE ST, LEES SUMMIT, MO 64063614 SE BRADFREE ST, LEES SUMMIT, MO
64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mitchell Schwarz	Not Ready	Monday, March 23, 2026

Informational:

1	Misc	The following areas inspected 1st layer sheet rock on separation walls 2nd layer screw pattern attic only
---	------	---

Corrective Action Required:

2	Misc	Fire caulk all penetrations
---	------	-----------------------------

Comments: