



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20112705, Building Permit - Commercial
Address: 1201 SW 3RD ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Mark Harding	Failed	Wednesday, May 23, 2012

Partial Correction
1 MISC

PERIMETER FOOTING FOR GAS STATION APPROVED
PENDING ENG REPORT ON PIERS FOR CANOPY
-PENDING REPORT ON TRASH ENCLOSER

Comments: