

HERMAN A. SCHARHAG CO., ARCHITECTS  
5836 CENTRAL STREET, KC, MO 64113  
816-914-5165

3/25/26

Joe Frogge  
Codes Administration  
220 SE Green Street  
Lee's Summit, MO 64063

Re: Re-submittal  
Summit Orchards  
410 NW Chipman Road  
PRCOM20252261

Dear Joe:

Attached are revised sheets, E101, E500, P102, MP200. These involve one more small change in the electrical service, along with showing a precast concrete grease interceptor in lieu of a plastic grease interceptor (this was a request from the field inspector). Thank you.

Sincerely,

*Jeff Schroeder*

Jeff Schroeder, RA, President  
Herman A. Scharhag Co., Architects