

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251415

Address: 626 SE GOLDEN LN, LEES SUMMIT, MO 64063628 SE GOLDEN LN, LEES SUMMIT, MO 64063630 SE
GOLDEN LN, LEES SUMMIT, MO 64063624 SE GOLDEN LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Partial	Thursday, March 26, 2026

Corrective Action Required:

1	Misc	3/24/26 Tyler S Dw does not have 4" of clean rock. Fail. 3-26-26 Dustin A, Dw has been formed and compacted. Approved to pour. this is for 624-630
---	------	--

Comments: