

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20251411

Address: 617 SE BRADFREE ST, LEES SUMMIT, MO 64063619 SE BRADFREE ST, LEES SUMMIT, MO 64063621  
SE BRADFREE ST, LEES SUMMIT, MO 64063615 SE BRADFREE ST, LEES SUMMIT, MO  
64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Drew Fischer	Failed	Friday, March 27, 2026

Corrective Action Required:

1	Misc	All
		-Address siding at grade issue
		615
		617
		619
		-laundry space at fur out, need to reset electrical box
		621
		-repair floor under shower/tub walls to provide full bearing (both bathrooms)
		-support supply vent duct up off of bath vent in primary bedroom

Comments: