

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250007
Address: 624 SE HIGHLAND PARK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Friday, March 27, 2026

Corrective Action Required:

2	Misc	624
		-provide clearance from siding to grade
		-complete draft stopping
		-seal penetrations into furr down in garage
		-seal top plate penetration at garage entry
		-seal top plate penetration garage entry closet
		-provide hold down strap from 2nd floor E exterior wall to truss below
		-seal dead space penetrations at fridge
		-seal bottom plate penetration in laundry
		-missing stud on E exterior wall 2nd floor
		-protect NM within 6' of attic access
		-secure NM for bath vanity light in stud bay
		-secure NM for light at for exterior light E exterior wall 2nd floor
		-

Comments: