

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250016
Address: 628 SE HIGHLAND PARK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Friday, March 27, 2026

Corrective Action Required:
2 Misc

- address siding from grade
- missing nails in hangers above half bath
- seal bottom plate penetration in laundry
- 2nd floor E exterior wall land electrical outside and secure NM
- seal bottom plate penetration in wall between E bedrooms
- seal around floor at 2nd floor tub plumbing
- fire block top of furr out wall in 2nd floor bathroom

Comments: