



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20116155, Building Permit - Residential
Address: 1721 NE WOODLAND SHORES CT, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Not Ready	Friday, May 25, 2012

Corrective Action Required
1 MISC

NOT READY FOR INSPECTION

*STILL TOO MANY STRUCTURAL DEFICIENCIES. I SEE TOO MANY FRAMING DEFICIENCIES. HAVE THE STRUCTURAL ENGINEER GO THROUGH THE HOUSE TO CORRECT THINGS THAT NEED TO BE CORRECTED.

INSPECTION TERMINATED.

THINGS TO NOTE SO FAR: NAILING PATTERN OR 1000 LB STRAP AT GARAGE PORTAL WALL.

TOE NAILING ALL JOISTS INTO PLATES

NAILING OF 2ND FLOOR JOISTS TO LVL AT CURVED PORTION AT REAR OF THE HOUSE. AS IS, THERE IS NO WITHDRAW RESISTENCE.

FULL BEARING FOR RED IRON I BEAM SUPPORTING SECOND FLOOR AT GARAGE ENTRY AND AT OPPOSITE SIDE BY STAIRS.

VENT KITCHEN SINK

ALL PLUMBING DWV DRILLED THROUGH STUDS REQUIRE STUD SHOES.

LVL OVER FRONT DOOR NOT FASTENED TOGETHER PROPERLY.

Comments: