

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20251401

Address: 611 SE GOLDEN LN, LEES SUMMIT, MO 64063613 SE GOLDEN LN, LEES SUMMIT, MO 64063615 SE GOLDEN LN, LEES SUMMIT, MO 64063609 SE GOLDEN LN, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection</b>	Dustin Agcopra	Failed	Monday, March 30, 2026

### Corrective Action Required:

1	Misc	3-30-26 Dustin A, Sewer is installed with tracer wire. There is backfall on the fitting before cleanout that needs to be ,corrected.
---	------	--

### Comments: