



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120753, Building Permit - Commercial
Address: 1306 SW MARKET ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Tuesday, May 29, 2012

Corrective Action Required
1 MISC

1. BOND AC DISCONNECT
2. BOND OUTLET BOX BEHIND COUNTER ON WALL.
3. COMPLETE FLOORING BEHIND COUNTER AREA.
4. COMPLETE FIRE DEPARTMENT ISSUES.
5. INSTALL COVER PLATE ON SWITCH BOX FOR FURNACE.

Comments: