

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251423

Address: 616 SE LINDBERG LN, LEES SUMMIT, MO 64063618 SE LINDBERG LN, LEES SUMMIT, MO 64063620
SE LINDBERG LN, LEES SUMMIT, MO 64063614 SE LINDBERG LN, LEES SUMMIT, MO
64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mitchell Schwarz	Partial	Tuesday, March 31, 2026

Informational:

1 Misc

1st layer screw pattern on party walls good in all units. Ok to cover
2nd layer screw pattern attic space okay
2nd layer tape and seal penetrations okay

Comments: