

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251411

Address: 617 SE BRADFREE ST, LEES SUMMIT, MO 64063619 SE BRADFREE ST, LEES SUMMIT, MO 64063621
SE BRADFREE ST, LEES SUMMIT, MO 64063615 SE BRADFREE ST, LEES SUMMIT, MO
64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mitchell Schwarz	Not Ready	Tuesday, March 31, 2026

Corrective Action Required:

1	Misc	All
		-Address siding at grade issue
		615
		617
		619
		621
		-repair floor under shower/tub walls to provide full bearing (both bathrooms)
		-support supply vent duct up off of bath vent in primary bedroom (not done)

Comments: