

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250024
Address: 627 SE WOOD LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, April 01, 2026

Informational:

1 Misc

Following areas inspected

- Exterior nailing,
- truss holddowns above a mechanical closet second story,
- trusses above front porch

Corrective Action Required:

2 Misc

- Stud shoe required at over board stud at garage/ powder room 1 st floor load bearing wall
- Nail off girder truss to plans in primary bedroom

Comments: