

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

### Inspection Summary

Permit #: PRCOM20251177  
Address: 7 NE SYCAMORE ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Shawn Hoffman	Partial	Wednesday, April 01, 2026

Corrective Action Required:  
1 FIRST FLOOR -Pre rock behind tubs and showers  
Corrective Action Required:  
2 SECOND FLOOR -Pre rock behind tubs and showers  
-Complete vertical fireblocking at all party walls  
205- add stud at exterior wall

Corrective Action Required:  
3 THIRD FLOOR Approved

**Comments:**