



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20114350, Building Permit - Commercial  
Address: 690 NW BLUE PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	John Borns	Passed	Wednesday, May 30, 2012

<b>Underground Electrical Inspection - Commercial</b>	John Borns	Partial	Wednesday, May 30, 2012
---	------------	---------	-------------------------

Partial Correction  
1 MISC

OK TO COVER WHEN READY 1" PVC BURIED CONDUIT FROM  
LOCATION OF L.P. #2 TO 70' NE;

**Comments: OK TO COVER WHEN READY EXTERIOR AND INTERIOR WALL FRAMING  
AND IN-WALL SYSTEMS. A/E TO SUBMIT AND RECEIVE APPROVAL OF DESIGN  
CHANGES BEFORE REQUEST IS MADE FOR ABOVE-CEILING INSPECTION.**