

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250044
Address: 656 SE WOOD LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, April 02, 2026

Corrective Action Required:

2	Misc	Inspection denied -revise plans to show as built (cripple wall in basement, using engineer trusses, load bearing locations, stud packs etc.) -provide complete set of plans on site
---	------	--

Comments: