



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114350, Building Permit - Commercial
Address: 690 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Wednesday, May 30, 2012
Partial Correction 1 MISC		OK TO COVER WHEN READY 1" PVC BURIED CONDUIT FROM LOCATION OF L.P. #2 TO 70' NE;	
Partial Correction 2 MISC		OK TO COVER WHEN READY THREE 4" PVC BURIED SECONDARY SERVICE CONDUITS FROM 5' N OF TRANSFORMER PAD TO BUILDING ENTRY	
Underground Electrical Inspection - Commercial	John Borns	Partial	Wednesday, May 30, 2012
Partial Correction 1 MISC		OK TO COVER WHEN READY 1" PVC BURIED CONDUIT FROM LOCATION OF L.P. #2 TO 70' NE;	
In-wall Inspection	John Borns	Passed	Wednesday, May 30, 2012

Comments: