



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20114350, Building Permit - Commercial  
Address: 690 NW BLUE PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Partial	Thursday, May 31, 2012

### Partial Correction

1 MISC

OK TO COVER WHEN READY 1" PVC BURIED CONDUIT FROM LOCATION OF L.P. #2 TO 70' NE;

### Partial Correction

2 MISC

OK TO COVER WHEN READY THREE 4" PVC BURIED SECONDARY SERVICE CONDUITS FROM 5' N OF TRANSFORMER PAD TO BUILDING ENTRY

### Partial Correction

3 MISC

OK TO COVER WHEN READY TWO 4" PVC BURIED TELEPHONE CONDUITS FROM BUILDING ENTRY TO E EDGE OF NORTH DRIVEWAY + ONE 1" PVC L.P. POWER CONDUIT FROM E EDGE OF NORTH DRIVEWAY TO 15' EAST

### Comments: