



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120721, Building Permit - Commercial
Address: 1041 NE SAM WALTON LN, Unit:B, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Failed	Friday, June 01, 2012

Corrective Action Required
2 MISC

ENSURE ALL ELECTRICAL BOX STAND-OFFS CONTACT
STRUCTURE FOR BOX SOLIDITY

Corrective Action Required
3 MISC

NEC 330.30: MC ELECTRICAL CABLE NOT SECURED WITHIN 12"
OF ENTRY TO SOME BOXES -- COLORADO JIM DOES NOT
RESIST TUGGING

Comments: