



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20120186, Building Permit - Commercial  
Address: 20 NE SAINT LUKES BLVD, Unit:100, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Commercial</b>	John Borns	Failed	Tuesday, June 05, 2012

### Partial Correction

1 MISC

FOLLOWING SPACES OK FOR USE & OCCUPANCY: C121; D131; 133 aka PHASE 2-B;

### Corrective Action Required

2 MISC

SEVERAL ELECT RECEPTS NOT HOT FOR TEST

### Corrective Action Required

3 MISC

NEC 408.4: LABELING OF ELECTRICAL CIRCUIT POSITIONS AT PANEL(S): EACH BREAKER POSITION MUST BE LABELED. MUST BE LEGIBLE; SPECIFIC. IF PANEL SCHEDULE IS USED NUMBER POSITIONS ON PANEL FRONT PER SCHEDULE. NO DITTO MARKS OR CONTINUATION SYMBOLS EXCEPT @ MULTIPLE POLE BREAKERS. LABEL UNUSED BREAKERS "SPARE"

<b>Alarm Test</b>	Joe Dir	Passed	Tuesday, June 05, 2012
-------------------	---------	--------	------------------------

<b>Occupancy Inspection - Fire</b>	Joe Dir	Passed	Tuesday, June 05, 2012
------------------------------------	---------	--------	------------------------

**Comments:**

