



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20110083, Building Permit - Commercial  
Address: 621 SW 3RD ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Residential</b>	John Borns	Passed	Wednesday, June 06, 2012
<b>Footing Inspection - Commercial</b>	John Borns	Passed	Wednesday, June 06, 2012

**Comments: OK TO PLACE WHEN READY CONCRETE ISLAND AT DRIVE-THROUGH.  
ONE DISTORTED BEND IN SITE LIGHTING PVC BURIED CONDUIT NEAR 3RD ST  
DRIVEWAY CORRECTED; OK TO COVER WHEN READY.**