



**CITY OF LEE'S SUMMIT
CODES ADMINISTRATION**

**220 SE GREEN ST.
P.O.BOX 1600**

**PHONE:
816-969-1200**

**FAX:
816-969-1201**

Certificate of Occupancy

Permit #: PRCOM20121140
Address: 315 SE DOUGLAS ST, LEES SUMMIT, MO 64063
Inspected On: Thursday, June 07, 2012
Inspected By: John Borns

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Full C of O	Thursday, June 07, 2012

Comments: COFO CONTINGENT ON:

INSTALL FACE PLATE ON ELECTRICAL RECEPTACLE HIGH ON WEST WALL OF REAR SPACE.

REVISE PANEL SCHEDULE IN ELECTRICAL SERVICE PANEL TO SHOW ODD POSTION NUMBERS ON LEFT -- EVEN ON RIGHT; NUMBER BREAKER POSITIONS ON DEAD FRONT ACCORDINGLY.