

# CITY OF LEE'S SUMMIT

## CODES ADMINISTRATION DEPARTMENT

220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200  
Fax (816) 969-1201

### PLAN REVIEW CONDITIONS

June 07, 2012

SPORTZ NUTZ  
910 NW BLUE PKWY, UNIT R  
LEE'S SUMMIT, MO 64086

Permit No: PRCOM20120446  
Project Title: SPORTZ NUTZ  
Project Address: 910 NW BLUE PKWY, Unit:R, LEES SUMMIT, MO 64086  
Parcel Number: 51700033300000000  
Location: SUMMIT FAIR LOTS 22A & 24A---LOT 22A  
Type of Work: NEW TENANT FINISH  
Occupancy Group: MERCANTILE  
Description: ESTABLISH OCCUPANCY

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

#### **Building Plan Review**

**Reviewed By: Michael Weisenborn**

**Approved**

1. This permit is to establish the occupancy type for the space as it was not previously occupied. Any items found on inspection shall be corrected and scheduled for a reinspection.

#### **Fire Plan Review**

**Reviewed By: Brian Austerman**

**Approved**

1. 2006 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

Action Required: Provide one 2A10B:C extinguisher for every 75' of travel distance. Verified at inspection

2. 2006 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

Action Required: Do not place shelving or stock in a way that will obscure or impair alarm notification devices. Verified at inspection

3. 2305.4 Aisle maintenance.

When restocking is not being conducted, aisles shall be kept clear of storage, waste material and debris. Fire department access doors, aisles and exit doors shall not be obstructed. During restocking operations using manual stocking methods, a minimum unobstructed aisle width of 24 inches (610 mm) shall be maintained in 48-inch (1219 mm) or smaller aisles, and a minimum unobstructed aisle width of one-half of the required aisle width shall be maintained in aisles greater than 48 inches (1219 mm). During mechanical stocking operations, a minimum unobstructed aisle width of 44 inches (1118 mm) shall be maintained in accordance with Section 2306.9.

Action Required: For information only

- ☒ Approved to issue per the listed conditions.  
☐ Do not issue per the listed conditions.  
☐ Approved to construct foundation only per the listed conditions.  
☐ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

\_\_\_\_\_  
Signature of Applicant

\_\_\_\_\_  
Date

\_\_\_\_\_  
Print Applicant Name

\_\_\_\_\_  
CompanyName

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***