



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20120184, Building Permit - Commercial  
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Thursday, June 07, 2012

Partial Correction  
1 MISC

OK TO COVER WHEN READY FOLLOWING COMPONENTS OF RATED ASSEMBLIES AT INTERIM CLOSURES AT ELEVATOR DOORS @ 1ST & 2ND FLOORS: FRAMING AND SHAFT LINER; 1ST LAYER 5/8" TYPE X GWB;

<b>In-wall Inspection</b>	John Borns	Partial	Thursday, June 07, 2012
---------------------------	------------	---------	-------------------------

Partial Correction  
2 MISC

OK TO COVER WHEN READY GWB WALLS FULL HEIGHT @ FOLLOWING LOCATIONS: AHU RM 147 NE CORNER FOR MOUNTING OF DP-E1-28-HA; 126 & 127 FOR EQUIPMENT INSTALL; TEMPORARY EGRESS CORRIDOR @ 117; INFILL BELOW WINDOWS ALONG (DD) FROM (3.8) TO (5.1); BEHIND HVAC WALL CHASE @ 136 & 138; 119B; 119C; 120; 121; 123; 123A; 123B; 123C; 123D; 123E; 124; 125; 129; 130; 131; 132; 134; 135; BULKHEAD ABOVE DOOR 140; FOR CABLE TRAY @ PART OF CORR 143; WALL PLANE ON (7) FROM (BB.9) TO (DD);

**Comments:**