



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20115556, Building Permit - Commercial
Address: 130 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Monday, June 11, 2012

Partial Correction
1 MISC

FRAMING AND ENCLOSED SYSTEMS OK TO COVER AT FOLLOWING LOCATIONS: CANOPY SOFFIT @ DOOR E113; GWB LID AT 113; WALLS @ 109, 113, 115; WALLS AND GWB SOFFITS & CEILINGS @ 101, 105, 112, 114; 122 W WALL AFTER BOCA PLATE IN PLACED TO PROTECT PVC FROM PENETRATION AND AFTER TOP PLATE OPENINGS ARE FIRE-BLOCKED

Comments: