



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20120446
Address: 910 NW BLUE PKWY, Unit:R, LEES SUMMIT, MO 64086
Inspected On: Monday, June 11, 2012
Inspected By: John Borns
Expiration Date: 6/21/2012 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Monday, June 11, 2012

Corrective Action Required:

1	MISC	IBC 1210.1: SURFACE OF RESTROOM FLOOR / WALL SURFACE TO 48" A.F.F WITHIN 24" OF WATER CLOSET OR URINAL AND TO 6" A.F.F. PERIMETER OF ROOM. MUST BE NON-ABSORBENT, SMOOTH.
---	------	---

Comments: