



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120827, Building Permit - Commercial
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Failed	Tuesday, June 12, 2012

Corrective Action Required
1 MISC

2" FLOOR DRAIN PIPING ON EXISTING 2" WASTE SYSTEM -- NO ISSUES ON WORKMANSHIP. VENTING NOT INSTALLED PER DRAWING. WRITTEN A/E RESPONSE TO LS CODES REQUIRED BEFORE COVERING.

Comments: