



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114350, Building Permit - Commercial
Address: 690 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Tuesday, June 12, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY PVC BURIED CONDUIT FROM LOCATION OF L.P. #2 TO 70' NE; NORTH OF BLDG; TO DUMPSTER ENCLOSURE; FROM L.P. #6 TO 7 TO 8 TO 9; WAIVED INSPECTION OF OFF-HOURS INSTALLATION OF DATA/COMM CONDUIT AT DRIVEWAY CROSSING;

Partial Correction
2 MISC

OK TO COVER WHEN READY THREE 4" PVC BURIED SECONDARY SERVICE CONDUITS FROM 5' N OF TRANSFORMER PAD TO BUILDING ENTRY

Partial Correction
3 MISC

OK TO COVER WHEN READY TWO 4" PVC BURIED TELEPHONE CONDUITS FROM BUILDING ENTRY TO E EDGE OF NORTH DRIVEWAY + ONE 1" PVC L.P. POWER CONDUIT FROM E EDGE OF NORTH DRIVEWAY TO 15' EAST

Comments: