



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20115556, Building Permit - Commercial  
Address: 130 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Tuesday, June 19, 2012

Partial Correction  
1 MISC

OK TO COVER WHEN READY ACT CEILING FRAMING &  
ABOVE-CEILING SYSTEMS AT FOLLOWING SPACES: 101; 104A;  
104B; 105; 110; 111; 114; 115; 120; 121; 122 EXCEPT WHERE SINK  
VENT MUST BE VTR

**Comments:**