



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114350, Building Permit - Commercial
Address: 690 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|-----------------------------|------------|-----------|--------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Hood/Duct Inspection | John Borns | Not Ready | Wednesday, June 20, 2012 |

Corrective Action Required
1 MISC

6/19 & 6/20 M.C. PERSONNEL WHO ARRIVED ON SITE HAD NO TEST LIGHT; NO KNOWLEDGE OF LIGHT TEST PROCEDURE

Comments: