



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O. BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20114544, Building Permit - Commercial  
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Friday, June 22, 2012
Partial Correction 1 MISC		OK TO COVER WHEN READY RATED ASSEMBLY COMPONENTS OF FREIGHT ELEVATOR SHAFT: LID COMPLETE INCLUDING FIRE CAULK; SHAFT 4TH & 5TH FLR COMPLETE INCLUDING FIRE CAULK;	
Partial Correction 2 MISC		CLOSURE AT 4TH FLR S.E. CORNER PER 2/A2.8: FRAMING + SHAFT LINER + 1ST & 2ND LAYERS OF 5/8" TYPE X GWB OK TO COVER WHEN READY  CLOSURE AT 3RD FLR S.E. CORNER PER 2/A2.8: FRAMING + SHAFT LINER OK TO COVER WHEN READY	
Partial Correction 4 MISC		OK TO COVER WHEN READY FOLLOWING COMPONENTS OF RATED ASSEMBLY @ AT PASSENGER ELEVATOR SHAFT DOOR OPENING TEMPORARY CLOSURES: 4TH & 5TH FLOOR DOOR OPENINGS @ ELEVATORS #1 & #2 COMPLETE INCLUDING FIRE CAULK;	
Partial Correction 5 MISC		OK TO COVER WHEN READY COMPONENTS OF RATED ASSEMBLY AT UTILITY SHAFT: 4TH & 5TH FLOOR COMPLETE INCLUDING FIRE CAULK;	

**Comments:**

