



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114350, Building Permit - Commercial
Address: 690 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	John Borns	Partial	Monday, June 25, 2012

Partial Correction
1 MISC

Inspected 13 pieces of hood on the ground with light for defects in the shop welded pieces. No violations. Need to inspect field welds.

Partial Correction
2 MISC

GREASE DUCT FIELD WELDS INSPECTED AND LIGHT TESTED -- OK

Comments: