



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114544, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, June 25, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY RATED ASSEMBLY COMPONENTS OF FREIGHT ELEVATOR SHAFT: LID COMPLETE INCLUDING FIRE CAULK; SHAFT @ 4TH & 5TH FLR COMPLETE INCLUDING FIRE CAULK; SHAFT @ 3RD FLR FRAMING + SHAFT LINER

Partial Correction
2 MISC

CLOSURE AT 4TH FLR S.E. CORNER PER 2/A2.8: FRAMING + SHAFT LINER + 1ST & 2ND LAYERS OF 5/8" TYPE X GWB OK TO COVER WHEN READY

CLOSURE AT 3RD FLR S.E. CORNER PER 2/A2.8: FRAMING + SHAFT LINER OK TO COVER WHEN READY

Partial Correction
4 MISC

OK TO COVER WHEN READY COMPONENTS OF RATED ASSEMBLY AT UTILITY SHAFT: 4TH & 5TH FLOOR COMPLETE INCLUDING FIRE CAULK;

Partial Correction
5 MISC

COMPONENTS OF RATED ASSEMBLY @ AT FREIGHT ELEVATOR SHAFT DOOR OPENING TEMPORARY CLOSURES: 5TH FLOOR DOOR OPENING FRAMING, SHAFT LINER + ONE LAYER 5/8" TYPE X GWB; 4TH FLOOR DOOR OPENING FRAMING + SHAFT LINER;

Comments:

