



**CITY OF LEE'S SUMMIT
CODES ADMINISTRATION**

220 SE GREEN ST.
P.O. BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20115556
Address: 130 NW MURRAY RD, LEES SUMMIT, MO 64081
Inspected On: Tuesday, June 26, 2012
Inspected By: John BornsJohn BornsJoe DirJoe Dir
Expiration Date: 7/12/2012 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Tuesday, June 26, 2012

Partial Correction:
1 MISC OK TO COVER WHEN READY ACT CEILING FRAMING & ABOVE-CEILING SYSTEMS AT FOLLOWING SPACES: 101; 104A; 104B; 105; 110; 111; 114; 115; 120; 121; 122 EXCEPT WHERE SINK VENT MUST BE VTR

Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Tuesday, June 26, 2012
--	------------	------------------	------------------------

Corrective Action Required:
1 MISC SINK VENT @ 122 MUST BE VTR

Corrective Action Required:
2 MISC ELECT RECEPT @ CHAPEL SW ARCED AT TEST -- THIS ROOM NOT TO BE OCCUPIED BEFORE REPAIR IS COMPLETED

Corrective Action Required:

3 MISC OBTAIN APPROVAL OF PLANNING & DEVELOPMENT DEPT

Corrective Action Required:

4 MISC OBTAIN APPROVAL OF FIRE DEPT

Corrective Action Required:

5 MISC OBTAIN APPROVAL OF WATER DEPT

**Occupancy Inspection -
Fire**

Joe Dir

Temporary C of O

Tuesday, June 26,
2012

Alarm Test

Joe Dir

Passed

Tuesday, June 26,
2012

Comments: